



Product Service

CERTIFICATE

No. B 126253 0002 Rev. 00

Holder of Certificate: **Shanghai Moorewatt Energy Technology Co., Ltd.**
3rd Floor, Building 2
No 200 Zhangheng Road
China(Shanghai) Pilot Free Trade Zone
201204 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Connector**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704072437102-00

Valid until: 2029-06-17

Date, 2024-06-18

(Yaqun Alex Liu)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICATE



CERTIFICATE

No. B 126253 0002 Rev. 00

Model(s): MW-015LLL-B0(LLL=001,.....,999),
 MW-025LLL-B0(LLL=001,.....,999),
 MW-015LLL-A(LLL=001,.....,999),
 MW-025LLL-A(LLL=001,.....,999),
 MW-025LLL-B1(LLL=001,.....,999),
 MW-015LLL-B1(LLL=001,.....,999),
 MT-02502-A(CT75A-2Z-01),
 MT-02502-C, MT-03202-A,
 MT-02502-F, MT-02502-B, MT-03202-B

Parameters:

Rated Voltage:	300VAC
Rated current:	16A(1.5mm ²) 25A(2.5mm ²) 32A(4~6mm ²)
Degree of Protection:	IP65/IP68(1m, 1h)
Temperature range (LLT-ULT):	-40°C -125°C
With or without breaking capacity:	Without(COC)

Tested according to: IEC 61984:2008
 EN 61984:2009